

Formica s.a.
Avda. Txomin Egileor, 54
ES- 48960 GALAKAO-VISCAYA
Spain

Handläggare, enhet
Ingvar Sahlin
Certification
033-16 56 67, ingvar.sahlin@sp.se

Datum
2006-02-10
Rev
2006-03-14

Beteckning
CEP503124-C

Testing for CE-marking of Formica Europé laminates CGS/EGS

SP Swedish National Testing and Research Institute has as Notified Body no. 0402, performed Initial type-testing of the products mentioned below, and our report may be used as support for an EC Declaration of Conformity according to the requirements in the harmonized standard EN 438-7:2005

Issued for Manufacturer/Factory

Formica s.a. Avda. Txomin Egileor, 54, ES- 48960 GALAKAO-VISCAYA, Spain

Product name and description

Formica Europé laminates CGS/EGS. High pressure Laminates (HPL), without fire retardant for use in Construction Works and in nominal sizes 4,0 – 20,0 mm.

Product name	Requirement	Declared value	Report
CGS/EGS	Resistance to immersion in boiling water product increase weight and thickness	< 0,6% resp. < 0,8%	P503124-01 A date 2005-10-21
	Resistance to wet conditions product increase weight	< 3 %	P503124-01 B date 2005-10-21
	Resistance to climatic shock	Rating 5	P503124-01C rev date 2006-01-24
	Flexural strength	Pass	---
	Release of formaldehyde	E1	---
	Thermal shock	Pass	P503124-01 A date 2005-10-21
	Reaction to fire	Euroclass C-s1, d0	P500075U date 2005-07-14

SP Swedish National Testing and Research Institute
Certification


Lemnat Månsson
Certification Manager


Ingvar Sahlin
Certification Officer

